



DETAIL NOTES:

1. PIPE SIZE VARIES.
2. THE CONCRETE BASE SHALL BE POURED TO THE MIDPOINT OF THE EXISTING PIPE AND 6-INCHES MINIMUM BELOW THE BOTTOM OF THE PIPE.
3. THE CONCRETE BASE SHALL BE POURED 1-FOOT ON EITHER SIDE OF THE MANHOLE SECTION (CENTERED) TO ALLOW FOR SOLID, FLAT BASE. (CONCRETE: 5.5 SACK MIX/3000 PSI - 28 DAY STRENGTH)
4. 12-INCHES OF COMPACTED CRUSHED SURFACING BASE COURSE TO 95% MAXIMUM DENSITY, OR PER THE CITY OF ANACORTES TESTING PROTOCOL.
5. BACKFILL AROUND THE FIRST MANHOLE SECTION SHALL BE CONTROL DENSITY FILL, MEETING THE CITY OF ANACORTES ENGINEERING SPECIFICATIONS.
6. CHANNEL FLOWLINE, PER DETAIL S-01 "FLOW CHANNEL TYPICAL".

SCALE: NOT TO SCALE
 DRAWN BY: S.L.

FILE: S-02 DOGHOUSE MH.DWG

EFFECTIVE DATE:
 07-20-2006

REVIEW BY DATE:
 05-31-2013

REVIEWER:
 BUCKENMEYER



DETAIL: S-02

DOGHOUSE MANHOLE
 DETAIL

APPENDIX A - STANDARD DRAWING 2011